


## ACCESSORIES FOR DFS2/4


- ✓ DHi11 Auxiliary Switch
- ✓ DFA Remote Actuators
- ✓ KA Terminal Shroud



Ordering reference: see below

<b><i>DHi11 Auxiliary Switch</i></b>	
1 N/C + 1 C/O contacts	
Selection of signalling function using a screwdriver:	
Position 1: On or Off	Position 2: Tripped

Adjust using a screwdriver



<b><i>DFA Remote Actuators</i></b>	
Remote actuators or automatic reclosing devices (ARDs) can only be installed in the associated part of the installation where access is restricted to "instructed" or "electrically" skilled persons - see Regulation 531.1.1. Before installing a remote actuator on an RCCB, complete a risk assessment to determine if the remote tripping or re-closing of the RCCB could create a hazard - see Electricity at Work Regulations -1989 for example Regulation 4(65)	
For selection of specific devices please click <a href="#">here</a>	



Have a question? Please contact us today

Tel: 01628 829133 email: [sales@doepke.co.uk](mailto:sales@doepke.co.uk)

**Doepke** UK Ltd

## **KA Terminal Shroud**

Optional Terminal shroud

For 2 pole device use 4 shrouds

For 4 pole device use 8 shrouds



Have a question? Please **contact us today**

Tel: **01628 829133** email: **sales@doepke.co.uk**

**Doepke** UK Ltd